



NOTES:

1. MATERIALS AND INSTALLATION CHAPTER 8 OF THESE STANDARDS.
2. DECOMMISSION SEPTIC TANK PER CHAPTER 8 OF THESE STANDARDS AND KING COUNTY HEALTH DEPARTMENT.
3. WATER AND SEWER LINE SEPARATION 10' HORIZONTALLY. IF WATER AND SEWER LINES CROSS, SEWER SHALL BE AT LEAST 18" BELOW THE WATER LINE.

NOT TO SCALE



**City of
Tukwila**

SANITARY SIDE SEWER

RESIDENTIAL

SHEET: **SS-02**

REVISION #1: **08.03**

APPROVAL: **B. SHELTON**